

CERTIFICATE OF CONFORMANCE

Acting under ASME A17.7.1/CSA B44.7.1 issued by Liftinstituut B.V.
identification number ANSI AECO #0842
(AECO = Accredited Elevator/Escalator Certification Organization)
Certification system 3 according to ISO/IEC 17067: 2013

Certificate no. : NA17-0842-1004-016-16 Revision no.: -

Description of the product : Polyurethane buffer

Type : P+S, Type D for a nominal speed up to 1.0 m/s (200 fpm)

Model no. : D5 (165 x 80 mm)
Load range 1.0 m/s (200 fpm): 750 - 2700 kg (1654 – 5953 lb)

Name and address of the manufacturer : P+S Polyurethan-Elastomere GmbH & Co.KG
Kielweg 17
49356 Diepholz
Germany

Name and address of the certificate holder : P+S Polyurethan-Elastomere GmbH & Co.KG
Kielweg 17
49356 Diepholz
Germany

Certificate issued on the basis of the following requirements : ASME A17.7-2007 / CSA B44.7-07
(I-3 Components)

Test laboratory / location : TÜV Nord Cert, Hannover, Germany

Date and number of the laboratory report : 23-08-2017, Report Nr 17 795 468376 100 (TÜV Nord Cert)

Date of verification of conformance : March 2017 – November 2017

Annexes with this certificate : Certificate of Conformance Report
no: NA17-0842-1004-016-016

Additional remarks : For GESRs, SPs and other information see supporting report.

Conclusion : The Component meets the requirements of the ASME A17.7-2007 / CSA B44.7-07, taking into account any additional remarks mentioned above.

Amsterdam

Date : 14-11-2017
Valid thru : 14-11-2020


ing. P.J. Peeters
Manager


Certification decision by