

CERTIFICATE OF CONFORMANCE

Acting under ASME A17.7.1/CSA B44.7.1 issued by Liftinstituut B.V.
identification number ANSI AECO #0842
(AECO = Accredited Elevator/Escalator Certification Organization)
Certification system 3 according to ISO/IEC 17067: 2013

Certificate no. : NA17-0842-1004-016-16 Revision no.: 1

Description of the product : Polyurethane buffer
Type : P+S, Type D for a nominal speed up to 1.0 m/s (200 fpm)

Model no. : D5 (165 x 80 mm)
Load range 1.0 m/s (200 fpm): 850 - 2500 kg (1874 – 5511 lb)

Name and address of the manufacturer : P+S Polyurethan-Elastomere GmbH &Co.KG
Kielweg 17
49356 Diepholz
Germany

Name and address of the certificate holder : P+S Polyurethan-Elastomere GmbH &Co.KG
Kielweg 17
49356 Diepholz
Germany

Certificate issued on the basis of the following requirements : ASME A17.7-2007 / CSA B44.7-07
(I-3 Components)

Test laboratory / location : Liftinstituut, Alphen aan den Rijn, Netherlands

Date and number of the laboratory report : None

Date of verification of conformance : March – November 2017, December 2018

Annexes with this certificate : Certificate of Conformance Report
no: NA17-0842-1004-016-16

Additional remarks : For GESRs, SPs and other information see supporting report.
This revision replaces certificate NA17-0842-1004-016-16 of
November 14th, 2017

Conclusion : The Component meets the requirements of the ASME A17.7-
2007 / CSA B44.7-07, taking into account any additional
remarks mentioned above.

Amsterdam

Date : 21-02-2019
Valid thru : 14-11-2020


ing. P.J. Peeters
Manager


Certification decision by