

CERTIFICATE OF CONFORMANCE

Acting under ASME A17.7.1/CSA B44.7.1 issued by Liftinstituut B.V.
identification number ANSI AEEO #0842
(AEEO = Accredited Elevator/Escalator Certification Organization)
Certification system 3 according to ISO/IEC 17067: 2013

Certificate no. : NA 12-0842-1004-008-08 Revision no.: 4

Description of the product : Polyurethane buffer

Trademark : ACLA

Model / Type no. : 300527.01, 300527.02, 300527.03 and 300527.04, load range
133 – 1994 kg for nominal speed up to 1.0 m/s

Name and address of the manufacturer : ACLA-WERKE GMBH
Frankfurter Str. 142-190
D-51065 Köln, Germany

Name and address of the certificate holder : ACLA-WERKE GMBH
Frankfurter Str. 142-190
D-51065 Köln, Germany

Certificate issued on the basis of the following requirements : ASME A17.7-2007 / CSA B44.7-07
(I-3 Certification of Components)

Test laboratory / location : ACLA-WERKE GMBH, Köln, Germany

Date and number of the laboratory report : February 7th, 2013, Test Report supporting to Certificate of
Conformance no. NA 12-0842-1004-008-08 revision 1

Date of verification of conformance : January – February 2012, January 2013, April 2014, April 2017,
March 2020

Annexes with this certificate : Certificate of Conformance Report
no: NA 12-0842-1004-008-08 rev. 4

Additional remarks : For GESRs, SPs and other information see supporting report.
This revision replaces certificate NA 12-0842-1004-008-08 rev. 3
of 13-04-2017

Conclusion : The Component meets the requirements of the ASME A17.7-
2007 / CSA B44.7-07, taking into account any additional
remarks mentioned above.

Amsterdam

Date : 23-03-2020
Valid thru : 23-03-2023



ing. P.J. Peeters
Manager Certification



Certification decision by