

CERTIFICATE OF CONFORMANCE

Acting under ASME A17.7.1/CSA B44.7.1 issued by Liftinstituut B.V.
identification number ANSI AECO #0842
(AECO = Accredited Elevator/Escalator Certification Organization)
Certification system 3 according to ISO/IEC 17067: 2013

Certificate no. : NA19-0842-1004-008-12 Revision no.: -

Description of the product : Energy accumulation type buffers with non-linear characteristics

Type : ACLA, AUTAN HE, 300401Fx, \varnothing 100 mm x 80 mm

Model no. : 300401F1, 300401F3, 300401F4, 300401F5, 300401F6

Name and address of the manufacturer : ACLA-WERKE GMBH
Frankfurter Str. 142-190
D-51065 Köln, Germany

Name and address of the certificate holder : ACLA-WERKE GMBH
Frankfurter Str. 142-190
D-51065 Köln, Germany

Certificate issued on the basis of the following requirements : ASME A17.7-2007 / CSA B44.7-07
(I-3 Certification of Components)

Test laboratory / location : Acla, Germany

Date and number of the laboratory report : None

Date of verification of conformance : December 2016 – December 2018

Annexes with this certificate : Certificate of Conformance Report
no: NA19-0842-1004-008-12

Additional remarks : Load range 1.0 m/s (200 fpm): 400 - 1550 kg (882 - 3417 lb)
Load range 0.63 m/s (125 fpm): 237 - 4008 kg (522 - 8836 lb)
For GESRs, SPs and other information see supporting report.

Conclusion : The Component meets the requirements of the ASME A17.7-2007 / CSA B44.7-07, taking into account any additional remarks mentioned above.

Amsterdam

Date : 04-03-2019
Valid thru : 04-03-2022


ing. P.J. Peeters
Manager


Certification decision by