

# CERTIFICATE OF CONFORMANCE

Acting under ASME A17.7.1/CSA B44.7.1 issued by Liftinstituut B.V.  
identification number ANSI AECO #0842  
(AECO = Accredited Elevator/Escalator Certification Organization)  
Certification system 3 according to ISO/IEC 17067: 2013

Certificate no. : NA19-0842-1004-008-16 Revision no.: -

Description of the product : Energy accumulation type buffers with non-linear characteristics

Type : ACLA, AUTAN HE, 300403Fx,  $\varnothing$ 165 mm x 80 mm

Model no. : 300403F1, 300403F3, 300403F4, 300403F5, 300403F6

Name and address of the manufacturer : ACLA-WERKE GMBH  
Frankfurter Str. 142-190  
D-51065 Köln, Germany

Name and address of the certificate holder : ACLA-WERKE GMBH  
Frankfurter Str. 142-190  
D-51065 Köln, Germany

Certificate issued on the basis of the following requirements : ASME A17.7-2007 / CSA B44.7-07  
(I-3 Certification of Components)

Test laboratory / location : Acla, Germany

Date and number of the laboratory report : None

Date of verification of conformance : December 2016 – December 2018

Annexes with this certificate : Certificate of Conformance Report  
no: NA19-0842-1004-008-16

Additional remarks : Load range 1.0 m/s (200 fpm): 999 - 4207 kg (2202 - 9275 lb)  
Load range 0.63 m/s (125 fpm): 699 - 5303 kg (1541 - 11691 lb)  
For GESRs, SPs and other information see supporting report.

Conclusion : The Component meets the requirements of the ASME A17.7-2007 / CSA B44.7-07, taking into account any additional remarks mentioned above.

Amsterdam

Date : 04-03-2019  
Valid thru : 04-03-2022

ing. P.J. Peeters  
Manager

Certification decision by